

FEATURES

- Energy saving luminaire with integrated occupancy controls
- Bi-level light control offers safety and security
- Ideal for stairwells, parking structures, restrooms and areas where maximum light levels are not needed when area is unoccupied
- A single low wattage 2' T8 lamp delivers constant light output while the 4' T8 lamps are controlled by an integral occupancy/daylight harvesting sensor
- White aluminum body allows for greater heat dissipation
- Tool-less access to ballast for ease of maintenance
- Can be surface mounted or suspended
- Multiple ballast options available for needed energy savings and light output
- Fail safe operation switches light level to 100% if sensor is damaged
- Optional battery backup available for emergency egress applications

PROJECT INFORMATION

Project Name _____

Type _____

Catalog No. _____

Date _____

HOUSING

White Aluminum 0.032" thick fixture body

ELECTRICAL

Standard class "P," thermally protected, auto-resetting HPF ballast, sound rated A. All ballast leads extend a minimum of 6" through access location. NEC/CEC-compliant ballast disconnect is standard.

LENS

Highly efficient acrylic lens with a linear refractive pattern for even illumination and excellent lamp obscuration.

OCCUPANCY SENSOR

Hubbell Building Automation Internally mounted Passive Infrared Occupancy/Daylight Harvesting sensor. Fail-safe feature will switch light level to 100% if the sensor is damaged. LED indicator for easy verification of coverage. Lens has a 1500 square-foot, 360° coverage area at a mounting height of 10 ft, and a 2:1 radius to height ratio coverage pattern. Sensor includes an adjustable time delay, and motion/photocell sensitivity.

CERTIFICATION

All luminaires are built to UL 1598 standards and bear appropriate UL and cUL or CSA labels. Damp location labeling is standard. Units are UL 924 listed when equipped with optional battery back-up and meet requirements of the life safety code /NFPA101.

ORDERING INFORMATION

EXAMPLE BIL4-232-EPLWU

BIL	4	-	2	32	-	U	-
MODEL	SIZE	LAMPS IN CROSS SECTION		LAMP TYPE	PRIMARY BALLAST	VOLTAGE	OPTIONS
BIL Bi-Level Luminaire	4 4'	2 Two		32 4' T8: 32, 30, 28, or 25 Watt and 2' T8: 17 Watt	EP Electronic T8, Programmed Start, 0.88 BF EPLW Electronic T8, Programmed Start, 0.77 BF EPHL Electronic T8, Programmed Start, 1.18 BF	U 120V-277V	EL Emergency Battery Pack, 2' lamp 500 lumens F0730 T8 Lamps Installed, 75 CRI, 3000K F0735 T8 Lamps Installed, 75 CRI, 3500K F0830 T8 Lamps Installed, 82 CRI, 3000K F0835 T8 Lamps Installed, 82 CRI, 3500K NYC NYC Compliant NYCU NYC Compliant, Union Labeled

UNOCCUPIED			OCCUPIED	
(1) 17 WATT T8 LAMP			(1) 17 WATT T8 LAMP & (2) 32 WATT T8 LAMPS	
Ballast Type	Watts	Lumens	Watts	Lumens
EP (0.88 BF)	15	989	74	4669
EPLW (0.77 BF)	15	989	62	4208
EPHL (1.18 BF)	15	989	90	5170

PHOTOMETRIC DATA

Test RWS-3-1x4-1L17-2L32-M4-CA-PHa Test Date 3/19/08

LUMINAIRE DATA

Luminaire	BIL4-232-EPHLU Photometry based on Photopia software simulation. For relative photometry contact Columbia Lighting. Miro 4 Reflector Acrylic Lens
Ballast	Electronic T8
Ballast Factor	1.00
Lamp	F32T8
Lumens per Lamp	2383
Watts	100
Shielding Angle	N/A
Spacing Criterion	0°= 1.27 90°= 1.41
Luminous Opening in Feet	Length: 3.99 Width: 0.50 Height: 0.34

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt.
0-30	1041	14.6	20.1
0-40	1742	24.4	33.7
0-60	3241	45.3	62.6
0-90	4599	64.3	88.9
0-180	5175	72.4	100.0


ENERGY DATA

Total Luminaire Efficiency	72.4%
Luminaire Efficacy Rating (LER)	N/A
IESNA RP-1-1993 Compliance	Noncompliant
Comparative Yearly Lighting Energy Cost per 1000 Lumens	\$N/A based on 3000 hrs. and \$0.08 per KWH

COEFFICIENTS OF UTILIZATION (%)

RCR	RW	80				70				50				0
		70	50	30	10	70	50	30	10	50	30	10	0	
1	75	71	67	64	72	69	65	62	64	61	59	50		
2	68	61	56	51	65	59	54	50	55	51	47	41		
3	61	53	47	42	59	51	46	41	48	43	39	34		
4	56	47	40	35	54	45	39	34	42	37	33	28		
5	51	42	35	30	49	40	34	29	38	32	28	24		
6	47	37	31	26	45	36	30	25	34	29	24	21		
7	44	34	27	23	42	33	27	22	31	25	21	18		
8	41	31	24	20	39	30	24	20	28	23	19	16		
9	38	28	22	18	36	27	21	18	26	21	17	15		
10	36	26	20	16	34	25	20	16	24	19	15	13		

INDOOR CANDELA PLOT




AVG. LUMINANCE (Candela/Sq. M.)

Average Luminance Angle	0.0	22.5	45.0	67.5	90.0
0	6950	6950	6950	6950	6950
30	6621	5988	5641	5575	5572
40	6291	5473	5170	5091	5241
45	6103	5055	4867	5060	5241
50	5589	4582	4639	5025	5245
55	5035	4122	4495	4911	5064
60	4053	3604	4167	4470	4504
65	3038	2933	3866	4216	4252
70	1809	2313	3605	3928	4006
75	941	1874	3224	3599	3816
80	522	1642	3058	3460	3622
85	267	1495	2954	3559	3726

RCR = Room Cavity Ratio

RC = Effective Ceiling Cavity Reflectance RW = Wall Reflectance

DIMENSIONAL DATA



NOTE: All dimensions are in inches; dimensions and specifications are subject to change without notice. Please consult factory or check sample for verification.